

UST Program Field Notice of Non-compliance

No. 068

The Environmental Protection Agency (EPA) is responsible for the enforcement of underground storage tank (UST) laws that protect human health and the environment. Pursuant to federal regulation at 40 CFR Part 280, during an inspection on

3/25/99


the following items of UST non-compliance were observed at your facility:


1	Description: Failure to maintain copies of the financial assurance mechanism in the EPA format (40 CFR 280.11(c))	Correction Required: Submit Endorsement or Certificate of Insurance in EPA regulatory format.	Deadline: 4/10/99
2	Description: A 6-month test of the corrosion protection system must be made after installation of a new system (40 CFR 280.31(b)(1))	Correction Required: Provide a copy of the six month corrosion test.	Deadline: 6 months from Installation date
3	Description:	Correction Required:	Deadline:
4	Description:	Correction Required:	Deadline:

WARNING

The EPA wishes to work cooperatively with you as the owner and/or operator of this facility to resolve the violations(s) listed above at this time. Therefore, no penalty will currently be assessed. However, if you fail to complete the above noted compliance task(s) before the listed deadline(s), you will become subject to citation and/or formal enforcement action. Such enforcement actions mandate compliance and carry monetary penalties as high as \$10,000 for every day of continued violation on each underground tank.

Notify your EPA contact person (listed below) immediately if you are unable to perform the required actions within the specified dates.

EPA Inspector	
Name:	Robert B. Cutler
Office Address:	USEPA 300 Desmond Dr. SE, Suite 102 Lacey, WA 98503
Phone:	360-753-9543 (FAX) -8080
Signature:	

Facility Information	
Name of Facility:	Smitty's Conoco
Facility ID #	4-260087
Address:	102 E. Toppenish Ave. Toppenish, WA
Contact:	Melissa Leos, Mgr.
Phone:	509-865-5909
Signature:	 (Signature acknowledges receipt only)